


## IM30-GOS

N54-R1



50/51, 51BF, 68, 78

- Two Overcurrent levels
- Two Current Unbalance levels
- Out-of-Step
- Blocking Output and Blocking Input for pilot wire selectivity coordination
- Breaker Failure protection
- Modbus Communication Protocol
- UL / CSA listed



Three-phase multifunction protection relay for Generator OUT-of-STEP protection with MHO supervision element and double blinder logic.


Selectable 1A and 5A current inputs; voltage input adjustable 100-125V.

- Real Time Measurements = IA - IB - IC - Uab - Zr - - IAB
- Maximum Demand and Inrush Recording = IA - IB - IC - Uab - SA - SB - SC

### Programmable Input Quantities

- **Fn** = System frequency : (50 - 60)Hz
- **In** = Rated primary current of phase Cts : (1 - 9999)A, step 1A
- **Uns** = PTs rated secondary voltage : (100 - 125)V, step 1V
- **Ib** = Generator rated current : (0.5 - 1.1)In, step 0.1In

### Connection Diagram



**1 - F50/51 (I>): First Overcurrent Element**


- ⊙ Current setting range :  $I > = (1 - 2.5)I_b$ , step 0.01I<sub>b</sub>
- ⊙ Instantaneous element : **0.03s**
- ⊙ Independent time delay :  $F(I >) = D: tI > = (0.05 - 30)s$ , step 0.01s
- ⊙ Dependent time delay (Standard Inverse) :  $F(I >) = SI$  ;  $tI > =$  time delay @ 5x[I >]

**2 - F50/51 (I>>): Second Overcurrent Element**

- ⊙ Current setting range :  $I >> = (1 - 12)I_b$ , step 0.1I<sub>b</sub>
- ⊙ Instantaneous element : **0.03s**
- ⊙ Independent time delay :  $tI >> = (0.05 - 3)s$ , step 0.01s

**F78 : Generator Out-of-Step**

- ⊙ Impedance characteristic angle :  $z = (0 - 359)^\circ$ , step 1°
- ⊙ Diameter of the MHO supervision circle :  $K1 = (50 - 300)\%Z_b$ , step 1%Z<sub>b</sub>
- ⊙ Offset of the MHO supervision circle :  $Kc = (0 - 200)\%Z_b$ , step 1%Z<sub>b</sub>
- ⊙ Position of blinder B1 :  $(0 - 0.5)K1$ , step 0.01K1
- ⊙ Position of blinder B2 :  $-(0 - 0.5)K1$ , step 0.01K1
- ⊙ N° of swings to enable tripping : **(1 - 5)**, step 1
- ⊙ tR Reset time of MHO supervision element : **(0.1 - 30)s**, step 0.1s


**F51BF : Breaker Failure Element**

- ⊙ Trip time delay :  $t_{BF} = (0.05 - 0.5)s$ , step 0.01s